

UKCA Type Examination Certificate

This is to certify that: 3M United Kingdom Plc
3M Centre
Cain Road
Bracknell
RG12 8HT
United Kingdom

Holds Certificate Number: UKCA 773222

In respect of:

Personal hearing protection to EN 352-2:2020 - Earplugs
Models: E-A-R™ Express™, E-A-R™ Push-Ins™ and No-Touch™

On the basis that BSI carried out the relevant Type Examination procedures under the requirements with the Regulation 2016/425 on Personal Protective Equipment, as amended to apply in GB (PPE) Annex V (Module B) and meets the relevant health and safety requirements specified in Annex II.

For and on behalf of BSI, an Approved Body for the above Regulation (Approved Body Number 0086):

Shahm Barhom, Group Product Certification Director

First Issued: 2022-11-01
Latest Issue: 2024-10-11

Effective Date: 2024-10-11
Expiry Date: 2027-10-31



UKCA Type Examination Certificate

No. UKCA 773222

Product Specification

Product Name: 3M™ Push-To-Fit Earplugs
Product Type: Hearing Protectors – Earplugs
Models: E-A-R™ Express™ (corded and uncorded)
E-A-R™ Push-Ins™ (corded and uncorded)
No-Touch™ (corded)

Technical Specification: Designated Standard EN 352-2:2020

Product Description: These earplugs are designed to be inserted into the ear canal to protect against hazardous noise and loud sounds. The Express and Push-Ins have been approved for both two-hand and one-hand fitting. The No-Touch has been assessed for two-hand fitting only.

EN 352-2 Classification: Disposable

First Issued: 2022-11-01

Latest Issue: 2024-10-11

Effective Date: 2024-10-11

Expiry Date: 2027-10-31

Page: 2 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Type Examination Certificate

No. UKCA 773222

Model : Express (corded and uncorded)

Attenuation values - Two-hand insertion technique

Test Frequency f (Hz)	63	125	250	500	1000	2000	4000	8000
Mean Attenuation Value MV (dB)	27.8	24.1	27.3	26.7	29.1	35.3	38.0	39.7
Standard Deviation SD (dB)	5.5	5.2	5.0	4.8	5.0	3.3	4.4	3.5
Assumed Protection Value APV _f (dB) (APV _f = MV-SD)	22.3	18.9	22.3	21.9	24.1	32.0	33.6	36.2

High, Medium and Low Frequency Attenuation Values and Single Number Rating

Value	MV (dB)	SD (dB)	APV (dB)
High Frequency Attenuation Value (H)	34.3	3.3	31
Medium Frequency Attenuation Value (M)	29.2	4.2	25
Low Frequency Attenuation Value (L)	27.2	4.4	23
Single Number Rating (SNR)	32.2	3.8	28

Attenuation values - One-hand insertion technique

Test Frequency f (Hz)	63	125	250	500	1000	2000	4000	8000
Mean Attenuation Value MV (dB)	26.4	22.4	25.8	25.6	28.9	35.3	37.4	39.1
Standard Deviation SD (dB)	5.8	3.9	4.5	3.6	4.8	4.3	3.6	3.6
Assumed Protection Value APV _f (dB) (APV _f = MV-SD)	20.6	18.5	21.3	22.0	24.1	31.0	33.8	35.5

High, Medium and Low Frequency Attenuation Values and Single Number Rating

Value	MV (dB)	SD (dB)	APV (dB)
High Frequency Attenuation Value (H)	34.3	3.5	31
Medium Frequency Attenuation Value (M)	28.7	3.8	25
Low Frequency Attenuation Value (L)	26.2	3.7	23
Single Number Rating (SNR)	31.8	3.6	28

Sizing

Nominal Diameter: Smallest – 7 mm Largest – 12 mm

First Issued: 2022-11-01

Latest Issue: 2024-10-11

Effective Date: 2024-10-11

Expiry Date: 2027-10-31

Page: 3 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

UKCA Type Examination Certificate

No. UKCA 773222

Model : Push-Ins (corded and uncorded)

Attenuation values - Two-hand insertion technique

Test Frequency f (Hz)	63	125	250	500	1000	2000	4000	8000
Mean Attenuation Value MV (dB)	35.5	31.3	35.3	36.5	35.7	37.8	39.4	40.4
Standard Deviation SD (dB)	5.0	4.4	5.0	4.9	4.2	4.5	3.2	3.9
Assumed Protection Value APV _f (dB) (APV _f = MV-SD)	30.5	26.9	30.3	31.6	31.5	33.3	36.2	36.5

High, Medium and Low Frequency Attenuation Values and Single Number Rating

Value	MV (dB)	SD (dB)	APV (dB)
High Frequency Attenuation Value (H)	37.6	3.4	34
Medium Frequency Attenuation Value (M)	36.2	3.9	32
Low Frequency Attenuation Value (L)	35.3	4.3	31
Single Number Rating (SNR)	38.0	3.5	35

Attenuation values - One-hand insertion technique

Test Frequency f (Hz)	63	125	250	500	1000	2000	4000	8000
Mean Attenuation Value MV (dB)	30.3	27.9	31.6	31.4	32.0	36.1	37.9	38.9
Standard Deviation SD (dB)	5.7	4.6	4.3	5.2	5.2	3.0	4.6	5.1
Assumed Protection Value APV _f (dB) (APV _f = MV-SD)	24.6	23.3	27.3	26.2	26.8	33.1	33.3	33.8

High, Medium and Low Frequency Attenuation Values and Single Number Rating

Value	MV (dB)	SD (dB)	APV (dB)
High Frequency Attenuation Value (H)	35.2	3.2	32
Medium Frequency Attenuation Value (M)	32.4	4.2	28
Low Frequency Attenuation Value (L)	31.2	4.2	27
Single Number Rating (SNR)	34.7	3.6	31

Sizing

Nominal Diameter: Smallest – 7 mm Largest – 12 mm

First Issued: 2022-11-01

Latest Issue: 2024-10-11

Effective Date: 2024-10-11

Expiry Date: 2027-10-31

Page: 4 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

UKCA Type Examination Certificate

No. UKCA 773222

Model : No-Touch (corded)

Attenuation values - Two-hand insertion technique

Test Frequency f (Hz)	63	125	250	500	1000	2000	4000	8000
Mean Attenuation Value MV (dB)	34.3	29.3	33.3	34.3	34.3	37.0	45.2	48.1
Standard Deviation SD (dB)	5.5	3.9	4.6	5.5	4.9	3.4	4.6	4.2
Assumed Protection Value APV _f (dB) (APV _f = MV-SD)	28.8	25.4	28.7	28.8	29.4	33.6	40.6	43.9

High, Medium and Low Frequency Attenuation Values and Single Number Rating

Value	MV (dB)	SD (dB)	APV (dB)
High Frequency Attenuation Value (H)	38.1	3.0	35
Medium Frequency Attenuation Value (M)	34.6	3.7	31
Low Frequency Attenuation Value (L)	33.2	3.9	29
Single Number Rating (SNR)	37.3	3.2	34

Sizing

Nominal Diameter: Smallest – 6 mm Largest – 14 mm

Packaged variants

In addition to the products referenced on this Certificate the standard industrial products may also be sold as market specific packaged variants. Such variants will be differentiated, and the Technical File(s) will be updated with the appropriate information.

Kits and packouts

The products referenced on this Certificate may also be combined with other 3M products into a kit or packout. There will be no change to the product, but the User Information may vary, in such instances the applicable Technical File(s) will be updated with the appropriate information.

First Issued: 2022-11-01

Latest Issue: 2024-10-11

Effective Date: 2024-10-11

Expiry Date: 2027-10-31

Page: 5 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

UKCA Type Examination Certificate

No. UKCA 773222

Certificate Administration Details

Technical File Reference:

Item	Technical File
3M™ Push-To-Fit Earplugs	TF0691

Certificate Amendment Record:

Issue date	Comments	BSI Review No.
November 2022	First issue.	0086:22:3701440
October 2024	Removal of E-A-R Flexible Fit HA Earplugs	0086:24:30162847

Certificate validity

The Certificate holder is responsible for ensuring that the Approved Body is advised of changes to any aspect of the overall process utilised in the manufacture of the product, failure to do so could invalidate the Certificate in respect of product manufactured following the introduction of such changes.

The validity of the Certificate for the products is also dependent on the maintenance of the UKCA Conformity to Type based on Quality Assurance of the Production Process, Annex VIII (Module D), as referenced on BSI issued Certificate UKCA 745215.

First Issued: 2022-11-01

Latest Issue: 2024-10-11

Effective Date: 2024-10-11

Expiry Date: 2027-10-31

Page: 6 of 6

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.